

ESL-TR-08-04-02


A Study of the Advanced Systems at the CMU Intelligent Workplace with an Evaluation of Potential Applications to Texas A&M International University

A Summary Final Report

Submitted by:

**David E. Claridge, Ph.D., P.E.
Xiangyang Gong
Malcolm Verdict
Kathryn Clingenpeel
Energy Systems Laboratory
Texas Engineering Experiment Station
Texas A&M University System**

April 2008



**ENERGY SYSTEMS
LABORATORY**

**Texas Engineering Experiment Station
Texas A&M University System**

Disclaimer

This report was prepared by the Energy Systems Laboratory (ESL) of the Texas Engineering Experiment Station (TEES) under contract to Carnegie Mellon University. Neither the ESL nor TEES nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe on privately-owned rights.

Reference herein to any specific commercial product, process or service by trade name, trademark, manufacturer or otherwise, does not necessarily constitute or imply its endorsement, recommendation or favoring by the ESL or TEES or any agency thereof. The views and opinions of the authors expressed herein do not necessarily state or reflect those of the ESL or TEES or any agency thereof.

Table of Contents

Table of Contents	iii
Acknowledgements	iv
Introduction	5
Simulation and Verification Study of the Radiant Mullions	5
Simulation Study of the Overhead Radiant Panels	5
The Impact of the Radiator Position on Heating Load and Thermal Comfort	6
Indoor Humidity Analysis and the Desiccant Ventilation Units	6
Comparison of IW Radiant System with a Single Duct VAV System	7
Potential Application of the IW Advanced Systems at Texas A&M International University.....	7
References	8

Acknowledgements

This project is made possible through financial support under contract 04-32548-22000 from the Carnegie Mellon University (CMU). Useful input from and discussions with Prof. Volker Hartkopf, Prof. David Archer, Dr. Hongxi Yin and others at CMU have contributed greatly to the work described herein.

Introduction

A detailed study has been conducted of the performance of several innovative aspects of the Intelligent Workplace (IW) at Carnegie Mellon University, a low energy consumption building that uses radiant heating, cooling and a desiccant ventilation unit. The following aspects have been studied in detail: the heat transfer process of radiant mullions and overhead radiant panels, the impact of the radiator position on heating load and thermal comfort, the influence of infiltration on indoor humidity in a radiantly cooled office with a solid desiccant ventilation unit, and an energy consumption comparison of the sensible heating and cooling systems with a single duct VAV system. Transferability of the advanced building technologies that are being studied at the IW was investigated by examining them to see if they could be applied in an advanced technology test bed at Texas A&M International University (TAMIU) in Laredo, Texas. Additionally, a sustainability assessment for the current TAMIU campus was performed with an analysis of the potential for TAMIU to obtain LEED certification from the US Green Building Council. This report summarizes the conclusions and observations of these studies.

Simulation and Verification Study of the Radiant Mullions

The IW radiant mullion system is one type of façade heating and cooling system. No detailed study of such systems was found in the available literature. The heat transfer process of window mullion radiators was studied and a group of models were developed to simulate the performance of radiant mullions. The simulation results were compared with ten days of measured data. The comparison found that the heat transfer models predicted the measured temperatures with root mean square errors (RMSE) of the hot water return temperature, mullion surface temperature, and window surface temperature of 0.90°F, 0.98°F and 1.15°F, respectively:

The performance study of radiant mullions showed that hot water and chilled water supply temperatures are the primary factors affecting the heating or cooling capacity of radiant mullions and the mullion surface temperature. The window surface temperature distribution is affected by the mullion surface temperature and the inside and outside air temperatures. The temperature gradient on the glazing surface within one foot from the mullions is much higher than in the central part of the window. The temperatures in the central 2 feet of a 4-foot window show almost no influence from the mullion surface temperature.

The conductive thermal resistance of the mullion double tubes and gap filling plays a decisive role in controlling the mullion and window frame temperatures. An increased mullion tube conductive resistance results in a lower surface temperature for heating and a higher surface temperature for cooling. The higher surface temperature for cooling may be intended to lower the risk of moisture condensation on the surface of the mullion in the cooling condition. However, the enhanced thermal resistance decreases the heating and cooling capacity of the mullion. If the mullions are only used for heating, a single tube structure would provide better performance.

From the design perspective, the window width or spacing between the mullions has little impact on the heating capacity or mullion surface temperature. However, the space between the mullions will somewhat affect the window inner surface temperature distribution and average window temperature.

Simulation Study of the Overhead Radiant Panels

The heat transfer principles of the overhead radiant panels were studied and a heat transfer model set up. The model can be solved for the supply water outlet temperature, average panel surface temperature and overall panel surface heat transfer coefficient. The study found that the

heating and cooling capacity of the overhead panel without top insulation is a semi-linear function of the supply water temperature when the flow rate is fixed.

The cooling capacity of the overhead radiant panel is around 45 Btu/(hr-°F) at a chilled water supply temperature of 55°F; it is greatly affected by the room air temperature and slightly affected by the water flow rate. The heating capacity of the overhead radiant panel is around 144 Btu/(hr-°F) at the hot water supply temperature of 120°F. Room air temperature and supply water flow rate affect the heating input of the overhead radiant panels. The heating capacity increases by 8.5% when the room air temperature drops from 72°F to 68°F, and it decreases 14.2% if the hot water flow rate is reduced to half of the design flow rate.

The thermal contact resistance between the water tubes and the aluminum radiant panels has a significant impact on the thermal performance of the overhead radiant panels. When the thermal contact resistance increases to 0.2 Btu/(hr-°F), the cooling capacity drops 18.6% and the heating capacity drops 20.6%. The thermal contact resistance should be reduced to be as small as possible in the design processes.

The Impact of the Radiator Position on Heating Load and Thermal Comfort

The position of the radiators in a radiantly heated office has been shown to impact the heating load and the thermal comfort distribution inside the room. When radiators are close to the window, the increase of window surface temperature is higher than when the radiator is located in the center of the ceiling. The energy savings relative to the convective air system depend on the outside air supply rate. When the outside air supply rate and the rate of infiltration increase, the energy savings of the radiant system also increase.

The control device used also affects the energy consumption of a radiant heating system. If the dry bulb temperature thermostat is used instead of an operative temperature thermostat in a radiantly heated space and the air temperature is set at the same point as that which is used for air heating, radiant heating will increase the heating load as much as 11.5% higher compared to the air heating for the cases studied.

On the basis of thermal comfort, radiators located close to the window can reduce down draft, prevent cold penetration inside a room and make the operative temperature distribution much more uniform than when the radiator is located in the center of the ceiling.

Indoor Humidity Analysis and the Desiccant Ventilation Units

The indoor humidity study found that the active desiccant ventilation system dries a space deeply and continuously, while a passive desiccant ventilation system dries a space more energy efficiently. The moisture removal capacity of a passive desiccant system depends on the dryness of the exhaust air. When a passive ventilation system is the only source of dehumidification, the system cannot remove moisture without post-desiccant cooling.

High infiltration is one of the main causes of condensation in a radiantly cooled space during summer. Radiant panels cannot work without condensation in a leaky space, even if the supply air is conditioned to 52°F, 0.008lb/lb. Pressurizing the space with ventilation air is one possible solution available for avoiding water condensation on the surface of radiant cooling panels in a leaky building. The infiltration and ventilation rate has a significant impact on energy consumption. The primary energy consumption was simulated to increase by 36% when the infiltration rate increases from 0.0 to 0.45 air changes per hour in the space studied as might be expected; at the same infiltration condition of 0.45 ACH, the primary energy consumption increases by 42% when the ventilation rate increases from 650 CFM to 1600 CFM (as is the case in the IW).

Comparison of IW Radiant System with a Single Duct VAV System

The IW used radiant heating and cooling with a passive desiccant ventilation unit before the winter of 2005. The passive desiccant ventilation system was replaced by an active desiccant ventilation system during the winter of 2005. A group of fan coil units are planned for installation in the southern zone to offer additional cooling in the future. The sensible heating and cooling system of mullions, radiant panels, “cool wave” chilled beams (with a slowly oscillating fan) and fan coils in the IW has been simulated. The daily and monthly thermal, electricity and primary energy consumption of the IW sensible heating and cooling system was compared with a single duct VAV air heating and cooling system. The results showed that the current system with an integrated active desiccant ventilation unit consumes about 28.5% more thermal energy, 2.8% less electricity and 5.6% more primary energy than a single duct VAV air heating and cooling system. The current system with a presumed integrated passive desiccant ventilation unit consumes 21.0% less thermal energy, 2.3% less electricity and about 11.4% less primary energy than a single duct VAV system. On the basis of thermal comfort, the current integrated active desiccant ventilation system can easily control the relative indoor humidity ratio below 50% (0.0091b/lb, 73°F) in the summer, while the integrated passive desiccant system and the air heating and cooling system cannot control the indoor humidity ratio very well. The relative indoor humidity ratio varies between 45% and 70% (0.0012lb/lb, 73°F) in the summer when using these two types of systems.

By assuming that the infiltration is close to zero and the ventilation is a value of 650CFM (a value that meets ASHRAE Standard 62) for the three systems, it was found that the primary energy consumption of all three systems would be substantially reduced as expected: 17.3%, 34.0%, and 29.8% for the air, integrated active, and passive systems, respectively. The primary energy consumption of the integrated passive desiccant system would be 24.8% less than the single duct VAV air system. The primary energy consumption of the integrated active desiccant system would be 15.7% less than the single duct VAV air system, and provides much better indoor humidity control.

Potential Application of the IW Advanced Systems at Texas A&M International University

Occupancy based control and other advanced building technologies that are being studied at the Intelligent Workplace at Carnegie Melon University were examined to see if they could be applied in an advanced technology test bed at Texas A&M International University (TAMIU) in Laredo, Texas. Additionally, a sustainability assessment for the current TAMIU campus was performed with an analysis of the potential for TAMIU to obtain LEED certification from the US Green Building Council.

First, occupancy-based controls that would shut off lighting, utilize power management features on computer equipment, and reduce airflow when a space is unoccupied were examined. This setup has been installed in an office at Texas A&M University. It was found that 75% of chilled water, 67% of hot water, 86% of HVAC electricity, and 60% of lighting and computer electricity could be saved annually in this office. This amounts to an estimated annual savings of \$525. The same controls were applied to the proposed green building at TAMIU and it was found that 82% of chilled water, 96% of hot water, 57% of HVAC electricity, and 46% of lighting and computer electricity could be saved annually. This amounts to an estimated \$203,422 annual savings from using these controls.

Secondly, advanced building technologies used at the Intelligent Workplace were examined to see if TAMIU should consider implementing them in an advanced technology test bed in the new green building. Biodiesel cogeneration was found to be economically infeasible

using the loads calculated for the building. This type of cogeneration system could be examined for backup generation but should not be used for the main power supply. A feasibility calculation for a radiant heating and cooling system with ventilation was performed and it was estimated that using one of these systems could have potential in the Student Success Center (SSC) at TAMU if the building envelope is designed correctly. Displacement ventilation could be implemented for research purposes in the test bed, but should not be implemented on a broader basis until more is known about the performance of these systems in hot and humid climates. Daylighting should be used in the new building, but designers should be careful to ensure that solar gains into the building are not significantly increased with the addition of daylighting.

Thirdly, a sustainability assessment of the current TAMU campus was performed. Several good practices and areas for improvement were identified in the areas of energy, water, waste and recycling, built environment, transportation, land use, consumable supplies and equipment, food, health and well-being, sustainability-related courses and research, sustainability-related campus organizations, and sustainability and campus leadership. Additionally, the current TAMU campus was examined to see what scope of work would be required to achieve LEED certification from the US Green Building Council. It was found that 39 credits are either achievable as-is, achievable with a policy change, or achievable with a minor retrofit scope. Achievement of 32-39 credits would allow TAMU to receive a LEED-certified rating for existing buildings.

References

This report is based on work presented in:

Claridge, D. E.; Verdict, M.; Clingenpeel, K., "Sustainability Assessment and a Roadmap for Green Campus Initiative, Texas A&M International University, Laredo, Texas," ESL-TR-06-10-01, Energy Systems Laboratory, Texas A&M University, October, 2006.

Claridge, D., Gong, X., and Archer, D.H., "Development of a Heat Transfer Model for the Integrated Façade Heating," *Proc. of 8th International Conference for Enhanced Building Operation*, San Francisco, CA, November 1-2, 2007, CD.

Clingenpeel, Kathryn Elaine, "Evaluation of Selected Energy Options For A Sustainable Campus In Texas," M.S. Thesis, Department of Mechanical Engineering, Texas A&M University, December, 2007.

Gong, X. and Claridge, D.E., "Impact of the Position of a Radiator to Energy Consumption and Thermal Comfort in a Mixed Radiant and Convective Heating System," *Proc. of 6th International Conference for Enhanced Building Operation*, Pittsburgh, PA, October 11-13, 2005, CD.

Gong, X. and Claridge, D.E., "Investigation of a Radiantly Heated and Cooled Office with an Integrated Desiccant Ventilation Unit," *Journal of Harbin Institute of Technology*, Volume 13, Sup., Oct. 2006. ISSN 1005-9113.

Gong, X. and Claridge, D.E., "Indoor Humidity Analysis of an Integrated Radiant Cooling and Desiccant Ventilation System," *Proc. of 7th International Conference for Enhanced Building Operations – Maximizing Building Energy Efficiency and Comfort*, Part I, Paper I-6-1, Shenzhen, China, November 6-8, 2006, 12 pp.

Gong, Xiangyang and Claridge, David E., "Impact of the Position of the Radiators on Energy Consumption and Thermal Comfort in a Mixed Radiant and Convective Heating System," *ASHRAE Trans.*, Vol. 113, 2007, Pt. 1, pp. 494-503.

Gong, Xiangyang, "Investigation of a Radiantly Heated and Cooled Office with an Integrated Desiccant Ventilation Unit," Ph.D. Dissertation, Department of Mechanical Engineering, Texas A&M University, August, 2007.

Gong, X., Claridge, D.E. and Archer, D.H., "Infiltration Investigation of a Radiantly Heated or Cooled Office," *Proc. of 8th International Conference for Enhanced Building Operation*, San Francisco, CA, November 1-2, 2007, CD.